

Connie Valenti

From: Jim Hopkins <jhopkins@berkeleyheightsfire.com>
Sent: Monday, May 24, 2021 3:53 PM
To: Connie Valenti
Subject: Fire Dept, P&F 1-21 725 Mountain Ave

Connie

I recommend a fire hydrant be installed 10 to 20 feet from Plainfield Ave

Jim Hopkins
Deputy Chief / Fire Official
Berkeley Heights Fire Dept
office: [908-464-0800](tel:908-464-0800)
cell: [908-415-2552](tel:908-415-2552)